



# Government of the People's Republic of Bangladesh

Department of Public Health Engineering

14, Shaheed Captain Monsur Ali Sarani,

Kakrail, Dhaka-1000.

[www.dphe.gov.bd](http://www.dphe.gov.bd)



Report Date : 21-Apr-2026

## Natore Pourashava Water Supply Information

### General Information

<b>Division</b>	Rajshahi	<b>Category</b>	A
<b>Circle</b>	Rajshahi Circle	<b>Pourashava Type</b>	District Pourashava
<b>District</b>	Natore	<b>Area (in sq. km.)</b>	14.80
<b>Construction Year</b>	1869	<b>No of Ward</b>	09

### Population

<b>According to Census 2011</b>	
<b>According to Census 2022</b>	94,950
<b>On Year 2022</b>	94,950

### Household

<b>According to Census 2011</b>	11,096
<b>According to Census 2022</b>	15,024
<b>On Year 2022</b>	14,200

### Roads (in km.) : 111.86

<b>Paved Road (km)</b>	91
<b>Herring Road (km)</b>	4.25
<b>RCC/CC Road (km)</b>	11.11
<b>Earthen Road (km)</b>	5.50

### Core Area Information

<b>Core Area (in sq. km.)</b>	14.80
<b>Core Ward Population</b>	94550
<b>House Holds in Core Area</b>	
<b>No of Wards in Core Area</b>	09
<b>Wards No in Core Area</b>	

## Water Supply Information

<b>Primary source of Water Supply</b>	Ground Water
<b>Present Water Demand (m<sup>3</sup>)</b>	1680
<b>Present Water Supply (m<sup>3</sup>)</b>	1290
<b>Water Supply Time (hr/day)</b>	09

### ❖ Production Tube Well Information

<b>PTW (Nos)</b>	<b>Functioning (Nos)</b>	<b>Non-Functioning (Nos)</b>
11	11	0

### ❖ Details of Production Tube Well

SI	Location	Construction Year	Dia of PTW(mm)	Discharge (m <sup>3</sup> /h)	Strainer Location(m)	Supply Time (hr/day)	Status (Functioning/ Non-Functioning/ )	Project Name
1	PTW-01 Old Bus Terminal	2011	350*150	119-120	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
2	PTW-02 Baro Harishpur	2011	350*150	124-125	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
3	PTW-03 Kandivita	2011	350*150	166-167	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
4	PTW-04 Buradarga Gorstan	2011	350*150	86-87	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
5	PTW-05 Alipur Upshahor	2001	350*150	127-128	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
6	PTW-06 Baro Harishpur	2011	350*150	80-81	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
7	PTW-07 PTI	1999	350*150	131-132	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
8	PTW-08 Chokboddonat	2019	350*150	101-102	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
9	PTW-09 Jolkol 1	1991	350*150	95-96	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
10	PTW-10 Jolkol 2	1994	350*150	133-134	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
11	PTW-11 Aliapur DPHE	1999	350*150	117-118	45.73-70.12	09	Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)

### ❖ Water Quality of PTW (mg/L)

SI	Location	Iron	Arsenic	Chloride	Manganese	Other	Test date
1	PTW-05 Alipur Upshahor	0.4	0.002	14	0.19		2021-10-14
2	PTW-02 Baro Harishpur	0.5	0.002	14	0.02		2022-03-14
3	PTW-03 Kandivita	0.6	0.005	12	0.06		2022-03-14
4	PTW-04 Buradarga Gorstan	1	0.005	14	0.20		2022-03-14

SI	Location	Iron	Arsenic	Chloride	Manganese	Other	Test date
5	PTW-06 Baro Harishpur	0.9	0.004	12	0.03		2022-03-14
6	PTW-07 PTI	1	0.004	18	0.11		2022-03-14
7	PTW-08 Chokboddonat	0.4	0.002	12	0.16		2022-03-14
8	PTW-09 Jolkol 1	0.6	0.005	18	0.28		2021-10-14
9	PTW-11 Aliapur DPHE	0.6	0.004	12	0.29		2022-03-14

#### ❖ Overhead Water Tank Information

OWT (Nos)	Functioning (Nos)	Non-Functioning (Nos)
3	0	3

#### ❖ Details of Overhead Water Tank

SI	Location	Construction Year	Capacity (m <sup>3</sup> )	Status (Functioning/ Non-Functioning / )	Project Name
1	OWT-01 Old Bus Terminal	2013	680	Non-Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
2	OWT-02 Mallikhati PTI	2013	680	Non-Functioning	Secondary Town Water Supply & Sanitation Project (STWSSP) (GoB-ADB)
3	OWT-03 Jolkol	2000	680	Non-Functioning	

#### ❖ Water Treatment Plant Information

WTP (Nos)	Functioning (Nos)	Non-Functioning (Nos)
2	0	2

#### ❖ Details of Water Treatment Plant

SI	Location	Water Source	Construction Year	Capacity (m <sup>3</sup> )	Working Hour(hr/day)	Status (Functioning/ Non-Functioning / )	Project Name
1	WTP-01 Millikhati PTI	Surface Water	2013	300		Non-Functioning	
2	WTP-02 Jolkol	Surface Water	2000	300		Non-Functioning	