



# Government of the People's Republic of Bangladesh

Department of Public Health Engineering

14, Shaheed Captain Monsur Ali Sarani,

Kakrail, Dhaka-1000.

[www.dphe.gov.bd](http://www.dphe.gov.bd)



Report Date : 17-Apr-2026

## Amtali Pourashava Water Supply Information

### General Information

<b>Division</b>	Barishal	<b>Category</b>	A
<b>Circle</b>	Barisal Circle	<b>Pourashava Type</b>	Upazila Pourashava
<b>District</b>	Barguna	<b>Area (in sq. km.)</b>	8.75
<b>Construction Year</b>	1998	<b>No of Ward</b>	9

### Population

<b>According to Census 2011</b>	28247
<b>According to Census 2022</b>	33077
<b>On Year 2022</b>	33077

### Household

<b>According to Census 2011</b>	5788
<b>According to Census 2022</b>	5900
<b>On Year 2022</b>	5900

### Roads (in km.) : 45

<b>Paved Road (km)</b>	22
<b>Herring Road (km)</b>	
<b>RCC/CC Road (km)</b>	8
<b>Earthen Road (km)</b>	15

### Core Area Information

<b>Core Area (in sq. km.)</b>	8.75
<b>Core Ward Population</b>	33077
<b>House Holds in Core Area</b>	5900
<b>No of Wards in Core Area</b>	09
<b>Wards No in Core Area</b>	

## Water Supply Information

<b>Primary source of Water Supply</b>	Ground Water
<b>Present Water Demand (m<sup>3</sup>)</b>	6000
<b>Present Water Supply (m<sup>3</sup>)</b>	3000
<b>Water Supply Time (hr/day)</b>	06

### ❖ Production Tube Well Information

<b>PTW (Nos)</b>	<b>Functioning (Nos)</b>	<b>Non-Functioning (Nos)</b>
4	4	0

### ❖ Details of Production Tube Well

SI	Location	Construction Year	Dia of PTW(mm)	Discharge (m <sup>3</sup> /h)	Strainer Location(m)	Supply Time (hr/day)	Status (Functioning/ Non-Functioning/ )	Project Name
1	PTW-01 Amtali Govt. College(South side)	1998	14*6	70	330.0984-359.664	06	Functioning	DANIDA Supported Water Supply Project.
2	PTW-02 Amtali Govt.College(North side)	1998	14*6	40	327.0504 -347.1672	06	Functioning	DANIDA Supported Water Supply Project.
3	PTW-03 Khantakata,Amtali Pourashava	2017	14*6	75	335.28-349.3008	06	Functioning	
4	PTW-04 Amtali Pourashava Office Compound	2017	14*6	40	310.896-341.376	06	Functioning	

### ❖ Water Quality of PTW (mg/L)

### ❖ Overhead Water Tank Information

<b>OWT (Nos)</b>	<b>Functioning (Nos)</b>	<b>Non-Functioning (Nos)</b>
2	2	0

### ❖ Details of Overhead Water Tank

SI	Location	Construction Year	Capacity (m <sup>3</sup> )	Status (Functioning/ Non-Functioning / )	Project Name
1	OWT-01 Near DPHE Office,Amtali Pourashava	2005	500	Functioning	DANIDA Supported Water Supply Project.
2	OWT-02 Khantakata, Amtali Pourashava	2021	500	Functioning	

### ❖ Water Treatment Plant Information